



PROJECT NORTH
FLOOR PLAN
 SCALE: 1/4" = 1'-0"

HVAC CONSTRUCTION NOTES

(APPLIES TO THIS DRAWING ONLY)

1	EACH 1-1/2" CONDENSATE DRAIN PIPE FROM ABOVE SHALL DISCHARGE TO MOP SINK.	6	EXTEND 4" EXHAUST FLUE VENT THRU ROOF FOR SINGLE HEATER INSTALLATION. SEE SCHEDULE ON DRAWING H-6.
2	SLEEVE REFRIGERANT PIPING THRU WALL AND ROUTE TO E-3 AND E-4 ON MEZZANINE ABOVE. INSTALL SHIELD PLATES TO PROTECT LINE IN WALL FROM FASTENERS.	7	EXTEND 6" COMMON EXHAUST FLUE VENT THRU ROOF FOR DUAL HEATER INSTALLATION. SEE SCHEDULE ON DRAWING H-6.
3	ROUTE 4" SHEETMETAL DRYER EXHAUST DUCT RISER EXPOSED ON WALL TO DBE-1 ON MEZZANINE. SEE DETAIL ON DRAWING H-5.	8	INSTALL EXHAUST FAN ON MFR'S ROOF CURB. SEE SCHEDULE ON DRAWING H-6.
4	INSTALL OUTDOOR CONDENSING UNITS ON OVERSIZED CONCRETE BASE PAD.	9	INSTALL WALL MOUNTED WELDING FUME EXTRACTOR UNIT WITH DUAL EXTRACTION ARMS. SEE SCHEDULE ON DRAWING H-6. COORDINATE VENT HEIGHT WITH OVERHEAD DOOR.
5	SLEEVE 4" COMBUSTION AIR INTAKE THRU WALL. PROVIDE MFR'S TERMINATION CAP. SEE SCHEDULE ON DRAWING H-6.		

MARCUM ENGINEERING, LLC
 500 SOUTH 17th STREET - PADUCAH, KENTUCKY 42002-0120
 PHONE - 270.444.9274 FAX - 270.443.1904
© 2010 MARCUM ENGINEERING, LLC

castleberry megregor swinford ARCHITECTS
 BENTON GAS SYSTEM
 Project No. 10560

HVAC FLOOR PLAN - BLDG. B

H-3
 of 6
 DATE 10/01/10