



PLAN NORTH
FLOOR PLAN
 SCALE: 1/4" = 1'-0"

ELECTRICAL CONSTRUCTION NOTES

(APPLIES TO THIS DRAWING ONLY)

1	LOCATE RECEPTACLE/VOICE OUTLET ABOVE COUNTERTOP/BACKSPLASH.	5	CONTRACTOR SHALL FURNISH, INSTALL AND CONNECT POWER AND CONTROLS FOR OVERHEAD DOORS. COORDINATE INSTALLATION WITH MANUFACTURER'S RECOMMENDATIONS.
2	LOCATE ALL RECEPTACLES IN AREAS 107, 108, 109, 110 AND OPEN BAY EQUIPMENT STORAGE (ALTERNATE) 44" FROM BOTTOM OF RECEPTACLE TO A.F.F.	6	FOR CONTINUATION SEE DRAWING U-1.
3	USE GFCI BREAKERS ON ALL CIRCUITS FEEDING AREAS 107, 108, 109, 110 AND OPEN BAY EQUIPMENT STORAGE (ALTERNATE).	7	
4	PROVIDED THE ALTERNATE IS NOT ACCEPTED, THEN CONTRACTOR SHALL FURNISH, INSTALL AND CONNECT WEATHERPROOF GFI RECEPTACLES AS INDICATED AND WIRED FROM CIRCUIT B2-31.	8	
		9	

MARCUM ENGINEERING, LLC
 500 SOUTH 17th STREET - PADUCAH, KENTUCKY 42002-0120
 PHONE - 270.444.9274 FAX - 270.443.1904
COPYRIGHT © 2010 - MARCUM ENGINEERING, LLC

POWER AND SPECIAL SYSTEMS FLOOR PLAN - BLDG. B

castleberry megregor swinford ARCHITECTS

BENTON GAS SYSTEM Project No. 10560

E-4
 of 13
 DATE 10/01/10